


REVISIONS				
ECO	REV	DESCRIPTION	DATE	APPROVED
362	0	RELEASE OF DRAWING	11/19/18	CJO



DIMENSIONS (INCHES)			
PART #	A	B	C
H2H425-A04-10-A0 H2H425-A06-10-A0	27.75	22.75	31
H2H425-E01-10-A0 H2H425-E03-10-A0 H2H425-E04-10-A0	27.75	22.75	32.25
H2H425-A07-10-A0	27.5	21.25	31.5
H2H425-E06-10-A0	26.25	19.5	30.75

NOTE
 1) MOUNT ON A FIRM, LEVEL FLOOR
 2) ALL PIPING TO DISCHARGE MUST BE INDEPENDENTLY SUPPORTED AND NOT IMPART STRESS TO UNIT PIPING

APPROVALS		DATE	TITLE:
DRAWN CJO		11/16/2018	GENERAL ARRANGEMENT RESIDENTIAL FIRE PROTECTION H2HOME 425 GAL, 1" PIPING, BASIC CONTROLS
CHECKED XXX		11/16/2018	
SCALE 1:24		SIZE B	
SHEET 1 OF 1		DWG. NO. G-218254	
			REV 0

UNLESS OTHERWISE SPECIFIED
 DIMENSIONS ARE IN INCHES
 TOLERANCES ARE:

FRACTIONS ±x	DECIMALS .xx ±1.0	ANGLES ±x°
-----------------	----------------------	---------------

THIS DRAWING AND ALL OF ITS CONTENTS ARE THE SOLE PROPERTY OF GENERAL AIR PRODUCTS, INC. DETAILS MAY CHANGE WITHOUT NOTICE. THE CONTENTS OF THIS DRAWING MAY NOT BE REPRODUCED OR INCORPORATED IN WHOLE OR IN PART IN ANY EQUIPMENT, NOR THE MANUFACTURE OF ANY PARTS, WITHOUT WRITTEN CONSENT OF GENERAL AIR PRODUCTS, INCORPORATED.

